

WAC 173-360A-0650 Line tightness testing. Owners and operators using line tightness tests must comply with the requirements of this section.

(1) **Standards.** Line tightness tests must be able to detect at least a 0.1 gallon per hour leak rate at one and one-half times the operating pressure with a probability of detection of at least 0.95 and a probability of false alarm of no more than 0.05.

(2) **Performance.** Line tightness tests must be performed:

(a) By or under the direct supervision of a service provider certified in accordance with Part 9 of this chapter; and

(b) In accordance with the manufacturer's instructions and any conditions or limitations specified in the certification of the method or equipment.

(3) **Reporting.** Line tightness tests must be reported to the department within thirty days using the applicable checklist provided by the department. The checklist must be completed by the service provider.

[Statutory Authority: Chapter 90.76 RCW. WSR 18-15-083 (Order 16-02), § 173-360A-0650, filed 7/18/18, effective 10/1/18.]