

**WAC 296-305-06507 Sleeping areas.** (1) All sleeping areas in fire stations must be separated from vehicle storage areas by at least one-hour fire resistive assemblies.

(2) Sleeping areas must be protected by smoke and carbon monoxide detectors.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 18-22-116, § 296-305-06507, filed 11/6/18, effective 12/7/18. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060 and 29 C.F.R. 1910.156, Fire brigades. WSR 13-05-070, § 296-305-06507, filed 2/19/13, effective 1/1/14. Statutory Authority: RCW 49.17.010, [49.17].050 and [49.17].060. WSR 96-11-067, § 296-305-06507, filed 5/10/96, effective 1/1/97. Statutory Authority: Chapter 49.17 RCW. WSR 88-14-108 (Order 88-11), § 296-305-06507, filed 7/6/88; Order 77-20, § 296-305-06507, filed 10/18/77 and Emergency Order 77-24, filed 11/17/77, effective 12/17/77.]