

WAC 296-307-45520 Provide fire protection in the vapor area.

You must:

- Provide a manual fire extinguisher near the tank that is suitable for putting out flammable and combustible liquid fires.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 03-10-068, § 296-307-45520, filed 5/6/03, effective 8/1/03.]