

**WAC 296-307-465 Definitions.**

**ACGIH.** American Conference of Governmental Industrial Hygienists.

**Adjacent area.** Any area within twenty feet (6.1 m) of a vapor area that is not separated from the vapor area by tight partitions.

**ANSI.** American National Standards Institute.

**Approved.** Approved or listed by a nationally recognized testing laboratory. Refer to Federal Regulation 29 C.F.R. 1910.7, for definition of nationally recognized testing laboratory.

**Autoignition temperature.** The minimum temperature required to cause self-sustained combustion without any other source of heat.

**Combustible liquid.** A liquid having a flashpoint of at least 100°F (37.8°C) and below 200°F (93.3°C). Mixtures with at least ninety-nine percent of their components having flashpoints of 200°F (93.3°C) or higher are not considered combustible liquids.

**Detearing.** A process for removing excess wet coating material from the bottom edge of a dipped or coated object or material by passing it through an electrostatic field.

**Dip tank.** A container holding a liquid other than plain water that is used for dipping or coating. An object may be immersed (or partially immersed) in a dip tank or it may be suspended in a vapor coming from the tank.

**Flammable liquid.** Any liquid having a flashpoint below 100°F (37.8°C), except any mixture having components with flashpoints of 100°F (37.8°C) or higher, the total of which make up ninety-nine percent or more of the total volume of the mixture.

**Flashpoint.** The minimum temperature at which a liquid gives off a vapor in sufficient concentration to ignite when tested by any of the measurement methods described in the definition of flashpoint in WAC 296-307-55060.

**Lower flammable limit.** The lowest concentration of a material that will propagate a flame. The LFL is usually expressed as a percent by volume of the material in air (or other oxidant).

**NFPA.** National Fire Protection Association.

**Vapor area.** Any area in the vicinity of dip tanks, their drain boards or associated drying, conveying, or other equipment where the vapor concentration could exceed twenty-five percent of the lower flammable limit (LFL) for the liquid in the tank.

**You.** The employer.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-465, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-465, filed 5/6/03, effective 8/1/03.]