

**WAC 296-96-24670 Hoistway requirements.** (1) Escape ladders shall be installed and shall extend the full length of the hoistway.

(a) Ladders shall be installed in a manner to provide access to an emergency exit and shall be located in a position so that in an emergency a person can safely transfer from the car platform to the ladder.

Note: Transfer is considered safe when a person can maintain 3 points of contact while making the transfer.

(b) An "IMPAIRED CLEARANCE" sign shall be posted at the bottom of a ladder when the face of the ladder is less than 30 in. from any structure.

(2) The minimum clearance between a car side and the hoistway enclosure is 1 in.

(3) The clearance between a car platform and a landing sill shall be at least 1/2 in. but not more than 1 1/2 in.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-24670, filed 8/31/18, effective 10/1/18.]