

WAC 480-100-333 Initial accuracy of electric meters. All meters must be in good order and adjusted to register as nearly correct as practicable prior to being put into service or returned to service following testing or other work. All meters in service must be sealed by the use of a sealing device acceptable to the commission.

[Statutory Authority: RCW 80.01.040 and 80.04.160. WSR 01-11-004 (Docket No. UE-990473, General Order No. R-482), § 480-100-333, filed 5/3/01, effective 6/3/01.]