

WAC 480-90-323 Meter set assembly location. (1) The customer must furnish a convenient and unobstructed location to install the meter set assembly that is acceptable to the gas utility.

(2) A meter set assembly may include a meter, regulator, valve, and adjacent components. The meter set assembly must be accessible to the utility to read, inspect, repair, test, and make changes.

(3) Residential and commercial meter set assemblies should be installed outside at the building wall. All meter set assemblies should be placed, whenever possible, away from doors, windows, building overhangs, intake ducts, and other outside areas where gas can accumulate and migrate into buildings. When it becomes necessary to locate meters away from the building wall or inside buildings, the gas utility must keep a record of these meter set assemblies, including in such record the location, installation date, and leak history. Utilities must submit copies of such records to the commission upon request.

(4) The meter set assembly must be protected with a protective barrier whenever damage by vehicles or marine traffic is likely to occur.

[Statutory Authority: RCW 80.01.040 and 80.04.160. WSR 01-11-003 (Docket No. UG-990294, General Order No. R-484), § 480-90-323, filed 5/3/01, effective 6/3/01.]