

**WAC 51-11C-40373 Section C403.7.3—Ventilation air heating control.**

**C403.7.3 Ventilation air heating control.** For ventilation air units with supplemental heating capacity that operate in conjunction with zone heating and cooling systems, supplemental heating shall not warm ventilation supply air to a temperature greater than 55°F (13°C).

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapters 19.27A and 19.27 RCW. WSR 22-14-091, 23-12-101, and 23-20-021, § 51-11C-40373, filed 7/1/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40373, filed 11/26/19, effective 7/1/20.]