

**WAC 51-11R-40390 Section R403.10—Pool and spa energy consumption.**

**R403.10 Energy consumption of pools and spas.** The energy consumption of pools and permanent spas shall be controlled by the requirements in Sections R403.10.1 through R403.10.4.2.

**R403.10.1 Heaters.** The electric power to heaters shall be controlled by an on-off switch that is an integral part of the heater mounted on the exterior of the heater in a location with *ready access*, or external to and within 3 feet (914 mm) of the heater. Operation of such switch shall not change the settings of the heater thermostat. Such switches shall be in addition to a circuit breaker for the power to the heater.

**R403.10.2 Time switches.** Time switches or other control method that can automatically turn off and on heaters and pump motors according to a preset schedule shall be installed for heaters and pump motors. Heaters and pump motors that have built in time switches shall be deemed in compliance with this requirement.

EXCEPTIONS:

1. Where public health standards require 24-hour pump operation.
2. Pumps that operate solar- and waste-heat-recovery pool heating systems.

**R403.10.3 Covers.** Outdoor heated pools and outdoor permanent spas shall be provided with a vapor-retardant cover, or other approved vapor retardant means.

EXCEPTION: Where more than 75 percent of the energy for heating, computed over an operating season of not fewer than three calendar months, is from a heat pump or on-site renewable energy system, covers or other vapor-retardant means shall not be required.

**R403.10.4 Residential pool pumps.** Pool pump motors may not be split-phase or capacitor start-induction run type.

**R403.10.4.1 Two-speed capability.**

1. Pump motors: Pool pump motors with a capacity of 1 hp or more shall have the capability of operating at two or more speeds with low speed having a rotation rate that is no more than one-half of the motor's maximum rotation rate.

2. Pump controls: Pool pump motor controls shall have the capability of operating the pool pump with at least two speeds. The default circulation speed shall be the lowest speed, with a high speed override capability being for a temporary period not to exceed one normal cycle.

**R403.10.4.2 Pump operation.** Circulating water systems shall be controlled so that the circulation pump(s) can be conveniently turned off, automatically or manually, when the water system is not in operation.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and chapter 19.27A RCW. WSR 23-02-060, 23-12-102, and 23-20-022, § 51-11R-40390, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160 and chapter 19.27 RCW. WSR 20-01-047, § 51-11R-40390, filed 12/9/19, effective 7/1/20. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40390, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40390, filed 2/1/13, effective 7/1/13.]