

WAC 51-50-0704 Section 704—Fire-resistance rating of structural members.

704.6.1 Secondary (nonstructural) attachments to structural members.

Where primary and secondary structural steel members require fire protection, any additional structural steel members having direct connection to the primary structural frame or secondary structural members shall be protected with the same *fire-resistive* material and thickness as required for the structural member. The protection shall extend away from the structural member a distance of not less than 12 inches (305 mm), or shall be applied to the entire length where the attachment is less than 12 inches (305 mm) long. Where an attachment is hollow and the ends are open, the *fire-resistive* material and thickness shall be applied to both exterior and interior of the hollow steel attachment.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0704, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-090, § 51-50-0704, filed 12/12/19, effective 7/1/20.]