

WAC 388-97-3140 Illumination levels in new buildings and additions. The nursing home must ensure:

(1) Lighting fixtures and circuitry provide at least the illumination levels appropriate to the task;

(2) Design takes into consideration that lighting systems normally decrease in output with age and dirt accumulation; and

(3) Light fixture locations and switching arrangements are appropriate for the needs of the occupants of the spaces and follow Illuminating Engineering Society (IES) recommendations for health care facilities.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-3140, filed 9/24/08, effective 11/1/08.]