

WAC 296-150V-1420 How are gas supply connections in a conversion vendor unit or medical unit identified? A label must be permanently attached on the outside of the exterior wall of the conversion vendor unit or medical unit adjacent to the gas supply connection which provides the following information:

- (1) The type of system (i.e., liquid petroleum system or natural gas system or combination liquid petroleum and natural gas system);
- (2) The appropriate Btuh input rating; and
- (3) If excess ("or more") Btuh input is allowed.
- (4) An example of a label would be: Natural Gas System, 250,000 Btuh or more.

[Statutory Authority: Chapter 43.22 RCW. WSR 99-18-069, § 296-150V-1420, filed 8/31/99, effective 10/1/99.]