

WAC 296-307-45560 Make sure a heating system used for drying objects does not cause a fire. The employer must make sure the heating system used in a drying operation that could cause ignition:

(1) Has adequate mechanical ventilation that operates before and during the drying operation;

(2) Shuts down automatically if a ventilating fan fails to maintain adequate ventilation;

(3) Is installed as required by NFPA 86-1999, Standard for Ovens and Furnaces.

Note: Some, or all, of the consensus standards (such as ANSI and NFPA) may have been revised. If the employer complies with a later version of a consensus standard, the employer will be considered to have complied with any previous version of the same consensus standard.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-45560, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-45560, filed 5/6/03, effective 8/1/03.]