

**WAC 16-229-060 Secondary containment of liquid bulk pesticides—
Discharge outlets or valves.** Secondary containment including prefabricated secondary containment, shall not have discharge outlets or valves. Discharge outlets or valves on existing secondary containment shall be sealed. Secondary containments may be interconnected.

[Statutory Authority: Chapters 15.58 and 17.21 RCW. WSR 00-23-074, § 16-229-060, filed 11/17/00, effective 12/18/00. Statutory Authority: RCW 15.54.800 and 15.58.040. WSR 93-22-093 (Order 5018), § 16-229-060, filed 11/2/93, effective 3/1/94.]