

WAC 296-150C-0990 Sealing wall exterior openings. All exterior wall openings or penetrations into the commercial coach around piping, ducts, plenums, or vents must be sealed with moisture-resistant material.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-0990, filed 10/23/96, effective 11/25/96.]