

WAC 296-150F-0630 When HVAC equipment is supplied with more than one CFM rating, which rating do I use? Where HVAC equipment manufacturers show multiple cubic feet per minute (CFM) ratings and/or multiple water gauge ratings, you must use the highest rated capacity.

[Statutory Authority: RCW 43.22.340, 43.22.350, 43.22.355, 43.22.360, 43.22.400, 43.22.432, 43.22.433, 43.22.434, 43.22.450, 43.22.480, and 43.22.485. WSR 00-17-148, § 296-150F-0630, filed 8/22/00, effective 9/30/00.]