

WAC 296-307-36409 What must employees do when equipment causes electrical shock? Employees must report all shocks received from electrical equipment, no matter how slight, immediately to you. The equipment causing the shock must be checked and any necessary corrective action taken immediately.

[WSR 97-09-013, recodified as § 296-307-36409, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-36409, filed 10/31/96, effective 12/1/96.]