

WAC 388-76-10805 Automatic smoke detectors. The adult family home must ensure approved automatic smoke detectors are:

- (1) Installed, at a minimum, in the following locations:
 - (a) Every bedroom used by a resident;
 - (b) In proximity to the area where the resident or adult family home staff sleeps; and
 - (c) On every level of a multilevel home.
- (2) Installed in a manner so that the fire warning is heard in all parts of the home upon activation of a single detector; and
- (3) Kept in working condition at all times.

[Statutory Authority: RCW 70.128.040 and chapters 70.128 and 74.34 RCW. WSR 07-21-080, § 388-76-10805, filed 10/16/07, effective 1/1/08.]