WAC 388-842-0060 What water temperature safety measures must be met? (1) The provider must regulate the facility's water temperature no higher than 120 degrees Fahrenheit.

(2) The provider must complete and document monthly water temperature checks.

[Statutory Authority: RCW 71A.12.030, 71A.12.380, 71A.12.380(1), and 42 C.F.R. 441.301. WSR 25-15-103, s 388-842-0060, filed 7/17/25, effective 8/17/25.]