

WAC 480-100-308 Meter location. (1) Subject to the utilities' requirements, customers must provide a place to install the metering equipment that is:

(a) Readily accessible to utility employees without risks of bodily harm; and

(b) Free from vibration, corrosive atmosphere, and abnormal temperatures.

(2) Upon request by a customer or a customer's representative, electric utilities must provide a written description of acceptable meter installation parameters applicable to the customer's electrical service needs.

[Statutory Authority: RCW 80.01.040 and 80.04.160. WSR 01-11-004 (Docket No. UE-990473, General Order No. R-482), § 480-100-308, filed 5/3/01, effective 6/3/01.]