

**WAC 51-11C-40212 Section C402.1.2—Equipment buildings.**

**C402.1.2 Equipment buildings.** Buildings that comply with all of the following shall be exempt from the building thermal envelope provisions of this code:

1. Are separate buildings with floor area no more than 500 square feet (50 m<sup>2</sup>).

2. Are intended to house electronic equipment with installed equipment power totaling at least 7 watts per square foot (75 W/m<sup>2</sup>) and not intended for human occupancy.

3. Have a heating system capacity not greater than 17,000 Btu/hr (5 kW) and a heating thermostat set point that is restricted to not more than 50°F (10°C).

4. Have an average wall and roof *U*-factor less than 0.200.

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40212, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40212, filed 2/1/13, effective 7/1/13.]