

WAC 51-11C-403254 Section C403.2.6.4—Loading dock and parking garage ventilation system controls.

C403.2.6.4 Enclosed loading dock and parking garage exhaust ventilation system control. Mechanical ventilation systems for enclosed loading docks and parking garages shall be designed to exhaust the airflow rates (maximum and minimum) determined in accordance with the *International Mechanical Code*.

Ventilation systems shall be equipped with a control device that operates the system automatically by means of carbon monoxide detectors applied in conjunction with nitrogen dioxide detectors. Controllers shall be configured to shut off fans or modulate fan speed to 50 percent or less of design capacity, or intermittently operate fans less than 20 percent of the occupied time or as required to maintain acceptable contaminant levels in accordance with the *International Mechanical Code* provisions.

Gas sensor controllers used to activate the exhaust ventilation system shall stage or modulate fan speed upon detection of specified gas levels. All equipment used in sensor controlled systems shall be designed for the specific use and installed in accordance with the manufacturer's recommendations. The system shall be arranged to operate automatically by means of carbon monoxide detectors applied in conjunction with nitrogen dioxide detectors. Garages and loading docks shall be equipped with a controller and a full array of carbon monoxide (CO) sensors set to maintain levels of carbon monoxide below 35 parts per million (ppm). Additionally, a full array of nitrogen dioxide detectors shall be connected to the controller set to maintain the nitrogen dioxide level below the OSHA standard for eight hour exposure. Spacing and location of the sensors shall be installed in accordance with manufacturer recommendations.

C403.2.6.4.1 System activation devices for enclosed loading docks. Ventilation systems for enclosed loading docks shall be activated by one of the following:

1. Gas sensors installed in accordance with the *International Mechanical Code*; or
2. Occupant detection sensors used to activate the system that detects entry into the loading area along both the vehicle and pedestrian pathways.

C403.2.6.4.2 System activation devices for enclosed parking garages. Ventilation systems for enclosed parking garages shall be activated by gas sensors.

EXCEPTION: A parking garage ventilation system having a total design capacity under 8,000 cfm may use occupant sensors.

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-403254, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.025, 19.27A.045, and 19.27.074. WSR 13-20-120, § 51-11C-403254, filed 10/1/13, effective 11/1/13. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-403254, filed 2/1/13, effective 7/1/13.]