

WAC 51-11C-40332 Section C403.3.2—Economizer heating system impact.

C403.3.2 Economizer heating system impact. HVAC system design and economizer controls shall be such that economizer operation does not increase building heating energy use during normal operation.

EXCEPTION: Economizers on VAV systems that cause *zone* level heating to increase due to a reduction in supply air temperature.

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40332, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.025, 19.27A.045, and 19.27.074. WSR 13-20-120, § 51-11C-40332, filed 10/1/13, effective 11/1/13. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40332, filed 2/1/13, effective 7/1/13.]