

WAC 51-11C-71021 Table B102—Acceptable occupancy densities, receptacle power densities and service hot water consumption.

**TABLE B102
Acceptable Occupancy Densities, Receptacle Power Densities
and Service Hot Water Consumption^a**

| Building Type | Occupancy Density^b ft²/Person (Btu/h • ft²) | Receptacle Power Density^c, Watts/ft² (Btu/h • ft²) | Service Hot Water Quantities^d Btu/h per person |
|----------------------|---|--|--|
| Assembly | 50 (4.60) | 0.25 (0.85) | 215 |
| Health/Institutional | 200 (1.15) | 1.00 (3.41) | 135 |
| Hotel/Motel | 250 (0.92) | 0.25 (0.85) | 1,110 |
| Light Manufacturing | 750 (0.31) | 0.20 (0.68) | 225 |
| Office | 275 (0.84) | 0.75 (2.56) | 175 |
| Parking Garage | NA | NA | NA |
| Restaurant | 100 (2.30) | 0.10 (0.34) | 390 |
| Retail | 300 (3.07) | 0.25 (0.85) | 135 |
| School | 75 (3.07) | 0.50 (1.71) | 215 |
| Warehouse | 15,000 (0.02) | 0.10 (0.34) | 225 |

- ^a The occupancy densities, receptacle power densities, and service hot water consumption values are from ASHRAE Standard 90.1-1989 and addenda.
- ^b Values are in square feet of conditioned floor area per person. Heat generation in Btu per person per hour is 230 sensible and 190 latent. Figures in parenthesis are equivalent Btu per hour per square foot.
- ^c Values are in watts per square foot of conditioned floor area. Figures in parenthesis are equivalent Btu per hour per square foot. These values are the minimum acceptable. If other process loads are not input (such as for computers, cooking, refrigeration, etc.), it is recommended that receptacle power densities be increased until total process energy consumption is equivalent to 25 percent of the total.
- ^d Values are in Btu per person per hour.

[Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-71021, filed 2/1/13, effective 7/1/13.]