

**WAC 51-51-1002 Section R1002—Masonry heaters.**

**R1002.2 Installation.** *Masonry heaters* shall be installed in accordance with this section and shall be a masonry heater type approved by the department of ecology. Masonry heaters shall comply with one of the following:

1. *Masonry heaters* shall comply with the requirements of ASTM E 1602; or

2. *Masonry heaters* shall be *listed* and *labeled* in accordance with UL 1482 or CEN 15250 and installed in accordance with the manufacturer's installation instructions.

**R1002.2.1 Combustion air and doors.** Masonry heaters shall be provided with both of the following:

1. Primary combustion air ducted from the outside of the structure to the appliance.

2. Tight-fitting ceramic glass or metal doors. Flue dampers, when provided, shall have an external control and when in the closed position shall have a net free area of not less than five percent of the flue cross sectional area.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-104, § 51-51-1002, filed 11/15/23, effective 3/16/24; WSR 16-03-025, § 51-51-1002, filed 1/11/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-068, § 51-51-1002, filed 2/1/13, effective 7/1/13.]