

WAC 51-54A-0105 Permits.

105.5.14.1 Lithium batteries. An operational permit is required for an accumulation of more than 15 cubic feet (0.42 m) of lithium-ion and lithium metal batteries, where required by Section 322.1.

105.5.32 Mobile food preparation vehicles. A permit is required for mobile preparation vehicles equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems.

105.6.25 Underground supply piping for automatic sprinkler system. A construction permit is required for the installation of the portion of the underground water supply piping, public or private, supplying a water-based fire protection system. The permit shall apply to all underground piping and appurtenances downstream of the first control valve on the lateral piping or service line from the distribution main to 1 foot above finished floor of the facility with the fire protection system. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

EXCEPTIONS: 1. When the underground piping is installed by the aboveground piping contractor.
 2. Underground piping that serves a fire protection system installed in accordance with NFPA 13D.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0105, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0105, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 21-04-003, § 51-54A-0105, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0105, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0105, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0105, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0105, filed 2/1/13, effective 7/1/13.]